

MAJOR POWER PLANT INSURANCE CLAIMS FILED BETWEEN MIDDLE 2006 AND MIDDLE 2009

2009	Nature of Loss	Place of Accident	Corporation Links
15.4 M	Fire damage to stacker reclaimer (Fire)	IPP Jimah, Lukut, Negeri Sembilan (Coal-fired)	Jimah Energy Ventures
95.5 M	Damage to transformer (MB)	IPP Pantai Remis – Lumut, Sitiawan, Perak (Gas-fired)	Malakoff
2008			
17.5 M	Consequential Loss due to failure to despatch power (CL)	IPP Tg. Kling, Melaka (Gas-fired)	Powertek
12.4 M	The blades sustained fractures / cut in varying degrees at compressed section (MB + Hull)	SESB, Sandakan	SESB
2007			
9.86 M	Damage to 1 unit 4.7 MW Stork Wartsila Genset (MB)	IPP, Sandakan, Sabah (Oil-fired)	Sandakan Power Corp or Stratavest
31.3 M	Damage to turbine Generator (MB)	IPP Kota Kinabalu (Sepanggar Bay) (Gas-fired)	Sepanggar Bay Corp.
15.3 M	Fire damage to transformers and switchgears	IPP Cheng, Melaka	Powertek
10.5 M	Damage to SGT1 transformer (MB)	IPP Plentong, Johor	YTL
10.12 M	Damage to combustor due to detachment of metal piece from inside the combustor (MB)	IPP Lumut, Perak	Malakoff
15.2 M	Rupture at combustor shell (MB)	IPP, KL Sentral	
5.1 M	Damage to DG unit crank pin bearing (MB)	IPP Melawa, Sabah	ARL Tenaga
2006			
18.4 M	Fire damage to auxiliaries and turbine compartment (IAR – Fire)	IPP Teluk Gong, Melaka (Gas-fired)	Powertek
6.23 M	Damage to stator / rotor of the alternator (Fire)	Hydro power station operator, Jeli, Kelantan (Hydro)	Pergau Dam
5.68 M	Turbine compressor blades sustained fractures / cuts at varying degrees	SESB, Patau-Patau, Labuan	SESB